

Village of Point Edward Water Department

135 Kendall St., Point Edward, Ontario, N7V 4G6 Phone 519-339-7273 Fax 519-337-5963 e-mail sloma@xcelco.on.ca

ANNUAL SUMMARY WATER REPORT 2009 TO COUNCIL

Date: Feb 23, 2010

As per regulation 170, an annual report must be submitted to council. It is also in the municipal office lobby. In this report I will give a brief summary.

QUALITY OF WATER COMING INTO POINT EDWARD WATER DISTRIBUTION SYSTEM

Water testing done in Point Edward

Microbiological testing done under section 8 (2) during this reporting period

	Number of Samples	Range of E.Coli or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of HPC Samples	Range of HPC Results (#-#)
Raw					
Treated					
Distribution	152	0	0	51	< 10 - 30

NOTE: Ecoli count in the treated water is **zero**. Anything higher can be lethal

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity		
Chlorine	824	.40 - 1.70
Fluoride (If the DWS provides fluoridation)		


THM	16.65 ug/l
------------	-------------------

Lead	Point Edward is under the reduced testing and next round of tests will be Dec 2010
-------------	--

THM is acceptable, lead testing note is above.

Quantity of water purchased by Point Edward. 444,396 cubic meters

The Flow Rate average per minute 0.843192 cubic meters



Jim Sloma C.E.T.