

Village of Point Edward Water Department

135 Kendall St., Point Edward, Ontario, N7V 4G6 Phone 519-339-7273 Fax 519-337-5963 jsloma@villageofpointedward.com

ANNUAL SUMMARY WATER REPORT 2014 TO COUNCIL

Date: Feb 13, 2014

As per regulation 170, an annual report must be submitted to council. It is also in the municipal office lobby. In this report I will give a brief summary.

QUALITY OF WATER COMING INTO POINT EDWARD WATER DISTRIBUTION SYSTEM

Water testing done in Point Edward

Microbiological testing done under section 10(2) during this reporting period

	Number of Samples	Range of E.Coli or Fecal Results (#-#)	Range of Total Coliform Results (#-#)	Number of HPC Samples	Range of HPC Results (#-#)
Raw					
Treated					
Distribution	159	0	0	56	< 10 - 40

NOTE: Ecoli count in the treated water is **zero**. Anything higher can be lethal

Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (#-#)
Turbidity		
Chlorine	535	.62 - 1.67
Fluoride (If the DWS provides fluoridation)		


THM	number of samples	4	12 - 25 ug/l
------------	--------------------------	----------	---------------------

Lead	4 tests done	Range <.02-. 06 ug/l
-------------	--------------	----------------------

THM is acceptable, lead testing met the standards

Month	Total Flow per Month Cubic Meters	Average per Day Cubic Meters
January	30,232	975.22
February	23,013	821..89
March	23,477	757.32
April	25,897	859.66
May	28,790	928.70
June	36,360	1,212
July	35,341	1,140.03
August	32,683	1,054.29
September	30,271	1,009.03
October	26,213	845.58
November	22,379	745.7
December	23,247	749.9

There no equipment to show peak daily flow. I will be requesting relief from regulatory requirements.



Jim Sloma C.E.T.