



Feb 25, 2026

Mayor & Council

Re: Safe Drinking Water Act, O. Reg. 170/03 Schedule 22 Summary Report

Attached is the 2025 Summary Report for the Village of Point Edward Distribution System. This report has been completed based on the information obtained from the Village records and in accordance with Schedule 22 of O. Reg. 170/03, under the Safe Drinking Water Act, which requires a Summary Report to be prepared not later than March 31st of each year for the preceding calendar year. This report covers the period of January 1 to December 31, 2025.

Schedule 22-2 (a) specifies that the summary report is given to, in the case of a drinking water system owned by a municipality, the members of the municipal council for the Village of Point Edward and is not intended for distribution to the Ministry of the Environment, Conservation and Parks.

Section 12 of O. Reg. 170/03 requires the Summary Reports to be made available for inspection by any member of the public during normal business hours, without charge. The reports should be made available for inspection at the office of the municipality, or at a location that is reasonably convenient for the users of the water system.

Sincerely,

Jason Verstraeten
Manager of Environmental Services
Village of Point Edward

cc. CAO Jim Burns



Annual Summary Report

Schedule 22

Village of Point Edward Distribution System

2025

Prepared for: The Corporation of the Village of Point Edward

**By: Jason Verstraeten
Manager of Environmental Services
Village of Point Edward**

Table of Contents

Section Number	CONTENTS	Page Number
1	<p>"Compliance with the Safe Drinking Water Act and Regulation 170/03"</p> <p>"Compliance with the Municipal Drinking Water License 036-101& Drinking Water Works Permit 036-201 and any orders applicable to the system "</p> <p>Statement of Compliance</p>	3
2	<p>"Non-Compliance with the Safe Drinking Water Act, Regulation 170/03 and the Municipal Drinking Water License 036-101 & Drinking Water Works Permit 036-201 and any orders applicable to the system "</p> <p>Details of the non-compliance issues as well as how and when any non-compliance issues were corrected.</p>	3
3	Summary and discussion of quantity of water supplied.	4
APPENDICES		
Appendix A	Annual volume record of the Village of Point Edward Distribution System January 1, 2025 – December 31, 2025	5

SECTION 1

Compliance with the Safe Drinking Water Act and Regulation 170/03

Compliance with the Municipal Drinking Water License & Drinking Water Works Permit

This report is a summary of water quality information for the Village of Point Edward Distribution System and published in accordance with Schedule 22 of Ontario’s Safe Drinking Water Act, Ontario Regulation 170/03 for the reporting period of January 01, 2025, to December 31, 2025. The Village of Point Edward Distribution System is categorized as a Large Municipal Residential Drinking Water System.

The Village of Point Edward Distribution System was operated and maintained in such a manner that the water supplied to the consumers serviced by the system satisfied all the requirements in the Safe Drinking Water Act, the Regulations and the MDWL 036-101 and DWWP 036-201.

SECTION 2

Non-Compliance with the Safe Drinking Water Act, Regulation 170/03 and MDWL & DWWP

The Drinking Water System did NOT have any non-compliances in 2025.

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Notice of Resolution
N/A					

SECTION 3

Summary and discussion of quantity of water supplied.

In accordance with Schedule 22-2 (3) *“the report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system.”*

1. *A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average daily flows and monthly total flows.*
2. *A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system’s approval must be discussed.*

Attached is Appendix A, are the average daily volumes (m³) and Monthly Total flows. Annual monthly average and comparison from the prior year with percentage change up or down.

The quantity of water supplied during the reporting period did not exceed the rated capacity of this facility. As can be seen in the Lambton Area Water Supply System Annual Summary Report the capacity of the plant supplying water to Point Edward is below the rated capacity. A copy of this report is posted on the Village of Point Edward website.

Appendix A

Village of Point Edward Distribution System Annual Volume Record for 2025

Month	Average Daily Volume (m ³)	Total Monthly Flow (m ³)
January	961	29,781
February	984	27,553
March	992	30,752
April	1024	30,725
May	1099	34,078
June	1468	44,031
July	1411	43,748
August	1351	41,888
September	1255	37,645
October	1025	31,788
November	821	24,636
December	752	23,311

Annual Monthly Totals – m³/month
Daily Average volume – m³/day

2025 Total Annual Usage – 399,936m³

2024 Total Annual Usage – 388,842m³

Increase 11,094 m³ (2.8 % increase)

Note: Village of Point Edward is not required to give Maximum Daily Flows as the system does not have the equipment required to provide this data. The MOECP has given written regulatory relief from this requirement. (MDWL Schedule D 2.1 page 13)