



February 10, 2016

Mayor & Council

Re: Safe Drinking Water Act, O. Reg. 170/03 Schedule 22 Summary Report

Attached is the 2015 Summary Report for the Village of Point Edward Distribution System. This report has been completed based on the information obtained from the Village records and in accordance with Schedule 22 of O. Reg. 170/03, under the Safe Drinking Water Act, which requires a Summary Report to be prepared not later than March 31st of each year for the preceding calendar year. This report covers the period of January 1 to December 31, 2015.

Schedule 22-2 (a) specifies that the summary report is given to, in the case of a drinking water system owned by a municipality, the members of the municipal council for the Village of Point Edward, and is not intended for distribution to the Ministry of the Environment.

Section 12 of O. Reg. 170/03, requires the Summary Reports be made available for inspection by any member of the public during normal business hours, without charge. The reports should be made available for inspection at the office of the municipality, or at a location that is reasonably convenient to the users of the water system.

Sincerely,

Jason Verstraeten
Manager of Environmental Services
Village of Point Edward

cc. CAO Jim Burns



Annual Summary Report
Schedule 22

Village of Point Edward Distribution System
2015

Prepared for: The Corporation of the Village of Point Edward

By: Jason Verstraeten
Manager of Environmental Services
Village of Point Edward

Table of Contents

Section Number	CONTENTS	Page Number
1	<p>"Compliance with the Safe Drinking Water Act and Regulation 170/03"</p> <p>"Compliance with the Municipal Drinking Water License 036-101"</p> <p>Statement of Compliance</p>	3
2	<p>"Non-Compliance with the Safe Drinking Water Act, Regulation 170/03 and the Municipal Drinking Water License 036-101"</p> <p>Details of the non-compliance issues as well as how and when any non-compliance issues were corrected.</p>	3
3	Summary and discussion of quantity of water supplied	3
APPENDICES		
Appendix A	Annual volume record of the Village of Point Edward Distribution System January 1, 2015 – December 31, 2015	4

SECTION 1

Compliance with the Safe Drinking Water Act and Regulation 170/03

Compliance with the Municipal Drinking Water License 036-101

This report is a summary of water quality information for the Village of Point Edward Distribution System and published in accordance with Schedule 22 of Ontario's Safe Drinking Water Act, Ontario Regulation 170/03 for the reporting period of January 1, 2015 to December 31, 2015. The Village of Point Edward Distribution System is categorized as a Large Municipal Residential Drinking Water System.

The Village of Point Edward Distribution System was operated and maintained in such a manner that the water supplied to the consumers serviced by the system satisfied all the requirements in the Safe Drinking Water Act, the Regulations and the MDWL 036-101.

SECTION 2

Non-Compliance with the Safe Drinking Water Act, Regulation 170/03 and MDWL & DWWP

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Notice of Resolution
NONE					

SECTION 3

Summary and discussion of quantity of water supplied

In accordance with Schedule 22-2 (3) "*the report must also include the following information for the purpose of enabling the owner of the system to assess the capability of the system to meet existing and planned uses of the system.*"

- 1. A summary of the quantities and flow rates of the water supplied during the period covered by the report, including monthly average daily flows and monthly total flows.*
- 2. A comparison of the summary referred to in paragraph 1 to the rated capacity and flow rates approved in the system's approval must be discussed.*

Attached in Appendix A, are the average daily volumes (m³) and Monthly Total flows.

The quantity of water supplied during the reporting period did not exceed the rated capacity of this facility.

Appendix A

Village of Point Edward Distribution System Annual Volume Record for 2015

Month	Average Daily Volume (m ³)	Total Monthly Flow (m ³)
January	795	24,649
February	872	24,405
March	901	27,942
April	840	25,198
May	989	30,648
June	1160	34,800
July	1254	38,866
August	1243	38,534
September	1192	35,762
October	1154	35,762
November	1164	34,911
December	909	28,175

2015 Total Annual Usage - 379,653 m³

2014 Total Annual Usage - 351,400 m³

Increase 28,253 m³ (8%)

Note: Village of Point Edward is not required to give Maximum Daily Flows as the system does not have the equipment required to provide this data. The MOECC has given written regulatory relief from this requirement.